

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

CATEGORY: 7210-1297:100

Page 1 of 1

CATEGORY: Flame Detector

LISTEE: Fire Sentry, 593 Apollo Street, Brea CA 92621
Contact: *David Daniels (714) 671-1100 Fax (714) 671-5821

DESIGN: Model FS2000 system with Model CM1-A dust-tight controller, SS2-A, SS2-AM, SS2-AH and TS2-A are suitable for indoor and outdoor use in Class I, Division 1, Group B, C, and D, Class II, Division 1 Group E, F, and G and Class III hazardous locations. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, hazardous area suitability and FM label.

APPROVAL: Listed as a flame detection system for use with separately listed compatible control units. The model FT2033 test lamp discussed in listee's data sheet is not part of this approval. Authority having jurisdiction should be consulted prior to installation.

*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 16, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager